

केन्द्रीय खनन अनुसंधान संस्थान

(वैज्ञानिक तथा औद्योगिक अनुसंधान परिषद्)

बरवा रोड, धनबाद-826 001

बिहार, भारत



Central Mining Research Institute

(Council of Scientific & Industrial Research)

BARWA ROAD, DHANBAD-826 001

BIHAR, INDIA

Dated: 08 July 1997.

NO. CMRI/TC/346.....

M/s. HANSU CONTROLS LIMITED
4-420, T.T.C. Industrial Area
M.I.D.C., MAHAPE
NAVI, MUMBAI-400 701.

Sub:- Flameproof Testing as per IS:2146-1981 of your Flameproof -
cum - Weatherproof Enclosure for 7 Nos. Push Button Sta-
tion/Pendent in cast aluminium alloy LM-6 construction,
designated by Type : HT-52. - REPORT ON.

Your Ref. No. CMRI/5899 Dated 17/06/97.

Dear Sirs,

Please find enclosed the test report (prototype) of the
above sample, submitted by you.

Charges of Rs.10.100/- (Rupees Ten thousand One hundred)
only involved towards the testing issuing the schedule have been
adjusted against the advance deposit made by you.

Kindly arrange to collect the sample within 90 days from the
date of receipt of this letter failing which CMRI would dispose
off the sample by public auction without further notice.

Kindly acknowledge receipt.

Thanking you.

Yours faithfully,

(C. Banopadhyay)
Scientist-in-charge
Testing Cell

Encl : As above.

Test Report in Triplicate.

Copy to (1) Sri J. Achari, Sc. E-II

फोन-निदेशक, Director
Phone - 0326-202326/203043

(2) Billing Section, PAX
203010/203070/203090

तार-मिनसर्च, धनबाद
Gram : MINSEARCH, Dhanbad

फैक्स/FAX
0326-202429

E-mail : director@cscmri.ren.nic.in / root@cscmri.ren.nic.in

कार्यालय के दिन : सोमवार से शुक्रवार तक Working days : Monday to Friday



के० ख० अ० स० परीक्षण प्रकोष्ठ CMRI TESTING CELL

केन्द्रीय खनन अनुसंधान संस्थान
CENTRAL MINING RESEARCH INSTITUTE

(Council of Scientific & Industrial Research)

बन्वा रोड, धनबाद-८२६००१ (भारत) BARWA ROAD, DHANBAD-826001 (India)

परीक्षण प्रमाण पत्र TEST CERTIFICATE



FIRST SCHEDULE

[For association with the report of tests sent (under cover of this office letter No. CMRI/TC/... dated. 08. July 1997) to M/s. HANSU CONTROLS LIMITED, 4-420, T.T.C. INDUSTRIAL AREA M.I.D.C., MAHAPE, NAVI MUMBAI-400 701, in respect of the equipment mentioned below submitted to CMRI for test.]

APPARATUS : Flameproof cum Weatherproof Enclosures for Push Button Station (7 Nos.) is having two flameproof enclosures cast integrally but separated by a common partition wall. One is the main enclosure for push buttons and the other is the terminal box enclosure. Each enclosure has its independent bolted cover having spigotted joints.

The main enclosure cover, which is fitted with relevant push buttons having flameproof joints & gaps as per the relevant standard, is fixed by 5 Nos. M6 x 25 mm long socket head cap screws with spring washers. The terminal box cover without any mounting on it is also fixed by M6 x 25 mm long socket head cap screws with spring washers. The no. of bolts in this case is only 4 Nos. The heads of these bolts are all effectively shrouded.

Flameproof terminals of sealed type are provided through the partition wall in between two enclosures. Endless neoprene "O"-rings are provided on each cover, outside the effective flamepath for IP-65 protection.

Name, ratings & warning inscription plate made of brass/ss is fixed permanently on the covers by rivets, stating "ISOLATE SUPPLY BEFORE OPENING".

The external cable entries are maximum 3 Nos. and shall be applied through certified flameproof double compression type cable glands. The entry sizes shall be 1/2", 3/4" ET/BSC/NPT/BSP or 2 Nos. 1" ET/BSC/NPT/BSP or their any combination.

The push button station is also certified for use as a indicating lamp or rotary switches, based on test & examination. The details are covered by the Second Schedule.

The electrical ratings of the unit, as declared by the applicant are above 16 Amps & 500 volts.

For further details, the drawing mentioned below may be consulted.

D R A W I N G :

The unit is designed and constructed as flameproof in accordance with the following drawings conforming to the requirements of IS:2148-1981.

DRG. NO. : HT 52 Rev. "0" dated 18/03/97.

al

के० ख० अ० स० परीक्षण प्रकोष्ठ
CMRI TESTING CELL

Continuation Sheet



MANUFACTURER & APPLICANT : M/s. HANSU CONTROLS LIMITED
A-420, TTC INDUSTRIAL AREA
MIDC, MAHAPE,
NAVI MUMBAI-400 701

Declarations by the applicant/manufacturers as to standards with which the apparatus complies in respects of :-

- (a) As to flameproof construction : IS:2148-1981
(b) As to general design rating : Not Declared.
& performance.
(c) As to weatherproof construction : IS:2147-1962 (For IP-65)

Note: The CMRI has however not checked and tested the compliance of the apparatus to any standards other than IS 2148-1981 and IS:2147-1962 (For IP-65).

Group Classification: Groups I, IIA & IIB only as per IS:2148-1981.

NOTES : (i) For group I application, the material of construction of the enclosure shall be of cast iron only, fitted with appropriate & approved cable sealing box & gland of Mining Type.

(ii) Composition of LM-6 alloy purported to be forming the material of construction of the enclosure has been declared by the manufacturer to be as follows (no sample of the alloy was drawn from the prototype enclosure for verifying the chemical composition declared)

COMPOSITION OF ALUMINIUM ALLOY LM-6 :

Copper	0.1% (Max)	Silicon	10 to 13% (Max)
Titanium	0.2% (Max)	Lead	0.1% (Max)
Tin	0.05% (Max)	Magnesium	0.1% (Max)
Iron	0.6% (Max)	Zinc	0.1% (Max)
Nickel	0.1% (Max)	Manganese	0.5% (Max)

Aluminium by difference 88%

As per section 5.1 of IS: 2148-1981, the enclosure may be of a material chosen for its lightness provided it does not give rise to other hazards like incentive frictional spark hazards. therefore, it should be appropriate that sample of material used for construction of the enclosure should be submitted for verification of its safe qualities as regards to frictional impact spark hazard and this test Report should be read in conjunction with the frictional spark incendivity tests report of the material of construction of the enclosure.

Accordingly, the applicant/manufacturer has submitted a sample for frictional incendivity test. The results of test is being issued under separate cover.

के० ए० व० सं० परीक्षण प्रकोष्ठ
CMRI TESTING CELL

Continuation Sheet

TEST CERTIFICATE

SCOPE OF CERTIFICATE :

Certificates issued by the certifying authority testify only that the apparatus has been found to comply with the Definitions of Flameproof Enclosure contained in the relevant Indian Standard specification. They do not vouch for the quality of the equipment in any other respect.

This Institute reserves the right to review, amend or withdraw this Test Report at any time, if considered necessary in the interest of safety.


S E C O N D S C H E D U L E

The following are alternative permissible variations to otherwise identical unit covered by this Test Report :

1. The alternate material of construction of the Push Button Station / Pendant may be cast iron instead of cast aluminium alloy LM-6 for application in Groups I, IIA & IIB atmosphere.

By replacement of Main Enclosure Cover (7 Nos. Push Button Station), the unit may be used as given below with their respective type designation :-

- (i) FLP/WP Enclosure for 7 Nos. Indicating Lamp, Type : HT-53
(Result of test enclosed)
- (ii) FLP/WP Enclosure for 5 Nos. Push button + 1 No. indicating lamp, Type : HS-52.
- (iii) FLP/WP Enclosure for 4 Nos. Switch, Type : HE-58.
(Result of test enclosed)
- (iv) FLP/WP Enclosure for 1 No. Switch, Type : HE-55.
- (v) FLP/WP DOL Starter for 10 HP Motor with 2 Nos. Push Button, Type : HT-56.
- (vi) FLP/WP Enclosure for Pole Box with Plain Cover, Type: HB-52
- (vii) FLP/WP Enclosure for Digital Temperature Indicator Control Box / Electronic circuit, Type HY-58.
(Result of test enclosure)



के. ए. ए. स. परीक्षण प्रकोष्ठ
CMRI TESTING CELL



Continuation Sheet

ROUTINE TEST

(Preliminary Pressure Test and Final External Ignition Test)

[Accompanies this office letter no. CMRI/TC/346...dt...08 July 1997 and pertains to cast aluminium alloy LM-6 constructed flame-proof enclosures for 07 Nos. Push Button Station/Pendent, designated by Type : HT-52 & its associated alternative enclosures, manufactured & submitted for test by M/s. Hansu Controls Ltd., MIDC, Mahape, Navi Mumbai-400 701.]

Date(s) of Test : 02/07/97

Conditions of Test :

		Gas	% in air
1. Explosive mixture used			
(a) Preliminary Pressure - Internal Test		Hydrogen/Methane 85:15	24.0
(b) Final External Ignition Test	- Internal External	-do- -do-	20.0 18.0

2. Ignition by inductive break spark : Location as stated .

3. Pressure recorded by "COMPUTER" through "PIEZO ELECTRIC TRANSDUCER and CHARGE AMPLIFIER manufactured by "KISTLER" of SWITZERLAND. Position as shown.

Test Ref.No.	Ignition	Gauge Position	Max. Pressure Bar	Time of Pressure rise in milliseconds	Remarks

(A) Test for observation & pressure recording :

(i) Main Enclosure cover fitted with 7 Nos. push button

PPM/139498	Body	Body	2.52	10.2	No evidence of distress
PPM/139499	Body	Body	2.34	13.5	-do-
PPM/139500	Body	Body	3.04	6.0	-do-

(ii) Main Enclosure cover fitted with 7 Nos. indicating lamp

PPM/139504	Body	Body	2.32	11.8	-do-
PPM/139505	Body	Body	2.17	11.7	-do-
PPM/139506	Body	Body	2.31	11.6	-do-

(iii) Main enclosure cover fitted with 4 Nos. switch

PPM/139507	Body	Body	2.31	11.6	-do-
PPM/139508	Body	Body	2.31	11.6	-do-
PPM/139509	Body	Body	2.22	11.6	-do-

al

के० ख० अ० स० परीक्षण प्रकोष्ठ
CMRI TESTING CELL



Continuation Sheet

(iv) Main enclosure cover fitted with glass window for indicator

PPM/139510	Body	Body	2.30	11.6	-do-
PPM/139511	Body	Body	2.38	11.8	-do-
PPM/139512	Body	Body	2.18	11.4	-do-

(v) Terminal Box

PPM/139501	Body	Body	1.66	10.8	-do-
PPM/139502	Body	Body	1.67	11.1	-do-
PPM/139503	Body	Body	1.82	11.1	-do-

(B) Tests with surrounding explosive atmosphere :

(i) Main Enclosure cover fitted with 7 Nos. push button

EIT/139513	No external Ignition.
EIT/139514	No external Ignition.
EIT/139515	No external Ignition.
EIT/139516	No external Ignition.
EIT/139517	No external Ignition.

(ii) Main Enclosure cover fitted with 7 Nos. indicating lamp

EIT/139523	No external Ignition.
EIT/139524	No external Ignition.
EIT/139525	No external Ignition.
EIT/139526	No external Ignition.
EIT/139527	No external Ignition.

(iii) Main enclosure cover fitted with 4 Nos. switch

EIT/139528	No external Ignition.
EIT/139529	No external Ignition.
EIT/139530	No external Ignition.
EIT/139531	No external Ignition.
EIT/139532	No external Ignition.

(iv) Main enclosure cover fitted with glass window for indicator

EIT/139533	No external Ignition.
EIT/139534	No external Ignition.
EIT/139535	No external Ignition.
EIT/139536	No external Ignition.
EIT/139537	No external Ignition.

(v) Terminal Box

EIT/139518	No external Ignition.
EIT/139519	No external Ignition.
EIT/139520	No external Ignition.
EIT/139521	No external Ignition.
EIT/139522	No external Ignition.

Ch

के० ख० म० स० परीक्षण प्रकोष्ठ
CMRI TESTING CELL

Continuation Sheet

TEST CERTIFICATE

EXCESS PRESSURE TEST (STATIC METHOD)

Date(s) of Test : 02/07/97

1. Pressure applied hydraulically.
2. Pressure recorded by "Pressure-Gauge" of the Hydraulic Testing Machine.
3. Position of application of Pressure : As stated.

Test Ref.No.	Position of application of pressure	Max.Pressure (Kg/sq.cm)	Remarks
--------------	-------------------------------------	-------------------------	---------

(i) Main Enclosure cover fitted with 7 Nos. push button

OPM/139538	Body	10.0	No evidence of distress
------------	------	------	-------------------------

(ii) Main Enclosure cover fitted with 7 Nos. indicating lamp

OPM/139540	Body	10.0	-do-
------------	------	------	------

(iii) Main Enclosure cover fitted with 4 Nos. switch

OPM/139541	Body	10.0	-do-
------------	------	------	------

(iv) Main Enclosure cover fitted with glass window for indicator

OPM/139542	Body	10.0	-do-
------------	------	------	------

(v) Terminal Box

OPM/139539	Body	10.0	-do-
------------	------	------	------

4. Details of Test: The tests were made on the above enclosures of the unit as per clauses 25.4.2.3 of IS:2148-1981.

(a) A pressure of 10.0 Kg/cm² was applied hydraulically to the above enclosures, and the pressure being maintained for one minute in each case, as required by clause 25.4.2.3 of IS: 2148-1981.

(b) The above pressure applied was equal to the pressure specified in Table 4 of IS:2148-1981, as it is more than 1.5 times reference pressure (PPM).

5. OBSERVATIONS :

The enclosures of the unit withstood the pressures applied without any visual evidence of distress.

al

6. COMMENTS :

The enclosures of the unit satisfy the test requirements of clause 25.4.2.3 of IS:2148-1981.

7. NOTE :

As a result of the tests the manufacturer will be required to test each and every enclosure to a static pressure of 10.0 Kg/cm² as mentioned in column III of above Table. The enclosures of the unit should not suffer any damage or deformation as a result of static pressure applied.

GENERAL OBSERVATIONS ON THE BEHAVIOUR OF THE ENCLOSURES DURING TEST :

The Flameproof cum Weatherproof Enclosures for 7 Nos. Push Button Station, Type : HT-52 in cast aluminium alloy LM-6 construction, and its associated terminal box enclosure and other alternative covers, sustained no damage as a result of the routine tests applied and the surrounding flammable atmosphere was not ignited. The structure also withstood the excess pressure test, when applied hydraulically, without any visual evidence of distress.

NOTE :

THIS UNIT IS ONLY FLAMEPROOF WHEN ALL CABLE ENTRIES HAVE EITHER A CORRECTLY FITTED FLP BLANKING PLUG OR FLP CABLE GLAND, COMPLETE WITH CABLE TERMINATED IN THE PROPER MANNER CABLE GLANDS AND BLANKING PLUGS FITTED MUST BE OF A TYPE APPROVED FOR USE WITH THIS UNIT.

(TESTING OFFICER)

Dated: 04 July 1997

Flame and Explosion Laboratory,
Central Mining Research Institute (CSIR)
Barwa Road, Dhanbad-826 001 (Bihar State)

इकाये वैज्ञानिक
परीक्षण प्रकोष्ठ
Scientist-in-Charge
Testing Cell



(DISCIPLINE HEAD)

समन्वय वैज्ञानिक
CO-ORDINATING SCIENTIST

के० ख० अ० स० परीक्षण प्रकोष्ठ
CMRI TESTING CELL

Continuation Sheet

TEST CERTIFICATE

TEST FOR IP-65 DEGREE OF PROTECTION

[Accompanies this office letter No. CMRI/TC/ 346 Dated 68
July 1997 and pertains to cast aluminium alloy LM-6 constructed
flameproof enclosures for 07 Nos. Push Button Station/Pendent,
designated by Type : HT-52 & its associated alternative enclo-
sures, manufactured & submitted for tests by M/s. Hansu Controls
Ltd., MIDC, Mahape, Navi Mumbai-400 701.]

**1. TEST AGAINST INGRESS OF DUST AS PER REQUIREMENTS LAID DOWN
AGAINST 1ST CHARACTERISTIC NUMERAL 6 OF IP-65 OF IS:2147-1962 :**

The test was conducted on the Push Button Station / Pendent
in a closed Test Chamber in which talcum powder (passing 1575
micron sieve) was maintained in suspension by an air current. The
amount of talcum powder used was 2 Kg. per cubic metre of the Test
Chamber. The equipment under test was hung inside the Test
Chamber and was connected to a vacuum pump of the Testing set-up.
The vacuum maintained inside the enclosures was a differential
pressure equivalent to 200 mm column of water. This condition
within the enclosures was maintained for 2 continuous hours
during which time air were drawn through the joints in the enclo-
sures. The test was then stopped.

The test was repeated three times and on examination after
each test it was observed that no dusts had entered inside the
enclosures.

**2. TEST AGAINST INGRESS OF WATER AS PER REQUIREMENTS LAID DOWN
AGAINST 2ND CHARACTERISTIC NUMERAL 5 OF IP-65 OF IS:2147-1962 :**

The test was performed by washing down the Push Button
Station / Pendent from every direction by means of a hose nozzle
of 12.5 mm inside diameter which was held 3 metre away from the
equipment under test with a water pressure corresponding to a
head of about 10 metre of water. The duration of the test was 15
minutes.

The test was repeated three times and on examination after
each test it was observed that no water entered the enclosures.

CONCLUSION : The Flameproof-om-Weatherproof Push Button
Station/Pendent in cast aluminium alloy LM-6 construction, desig-
nated by Type : HT-52, under reference, meets the test require-
ments of IS:2147-1962 in respect of IP-65 Degree of Protection.

(TESTING OFFICER)

इसारी वैज्ञानिक
परीक्षण प्रकोष्ठ
Scientist-in-Charge
Testing Cell

(DISCIPLINE HEAD)

Dated 04 July 1997.
Flame and Explosion Laboratory,
Central Mining Research Institute (CSIR),
Barwa Road, Dhanbad-826 001 (Bihar State)

समन्वय वैज्ञानिक
COORDINATING SCIENTIST